

An Assessment of
City of Plant City WWTP
Hillsborough County
NPDES #FL0026557
Sampled March 1998

FILE COPY
DO NOT REMOVE

December 1998

Biology Section
Division of Administrative and Technical Services
Bureau of Laboratories

Comprehensive Quality Assurance Plan No. 870346G

Department of Environmental Protection

Results of Inspections

Discharger: Plant City WWTP
County: Hillsborough
NPDES Number: FL0026557
State Permit Expiration Date: 02 February 2002

Toxics Sampling Inspection (XSI)

Date Sampled: 02 March 1998

Results: The herbicide, atrazine, was detected in the facility's effluent (0.14 µg/L) at a concentration below chronically toxic levels (AQUIRE 1991). Aluminum, copper, iron, lead, and zinc were detected in the effluent at levels that complied with Class III water quality standards.

Compliance Biomonitoring Inspection (CBI)

Date Sampled: 02 March 1998

Results: The effluent was not toxic to the invertebrate, *Ceriodaphnia dubia*, or the fish, *Cyprinella leedsii*.

Impact Bioassessment Inspection (IBI)

Date Sampled: 02 March 1998

Results: Benthic macroinvertebrates were not collected due to extreme flooding. Phytoplankton communities did not reflect the elevated nutrients or AGP values. The control site had more taxa (35 taxa) and higher diversity (4.1) than the test site (25 taxa and 3.9 diversity). The algal density was lower at the test site compared to the control site. Both values were low relative to the nutrient levels. Chlorophyll *a* was undetected at both sites.

Water Quality Inspection (WQI)

Date Sampled: 02 March 1998

Results: Most of the nutrients were higher at the control site than at the test site. Orthophosphate was 0.64 mg/L at the control site and 0.46 mg/L at the test site. Total phosphorus and ammonia followed the same trend. However, nitrate+nitrite levels were higher at the test site (0.49 mg/L) than the control site (0.11 mg/L). The effluent nitrate+nitrite was 1.8 mg/L. TKN was comparable at both sites. AGP at the control site (13.1 mg dry wt/L) and the test site (29.6 mg dry wt/L) were above the 5 mg dry wt/L "problem threshold" (Raschke and Shultz 1987). The effluent had an AGP value of 49.1 mg dry wt/L.

Introduction

The city of Plant City WWTP is a domestic wastewater treatment facility and disposal site located in Hillsborough County, Florida (see maps in Appendix). The facility is a Type I activated sludge plant with screening and degritting, followed by aeration and clarification. Flow is polished in a hyacinth treatment pond, then filtered, chlorinated, and dechlorinated prior to discharge. A portion of the effluent is reused and the remaining effluent is discharged into the East Canal. The design flow, and the flow during this study was 8 MGD. Six million gallons were discharged into the receiving waters and the other two million gallons were reused.

The purpose of this investigation was to establish a baseline for the Plant City WWTP as it has changed its outfall from the West-side Canal to the East Canal. This baseline study was requested by Domestic Wastewater Compliance personnel.

This facility has had previous violations of fecal coliform counts, total suspended solids, total residual chlorine, and calibration of equipment (see Facility Summary in Appendix). During this study, the facility diverted its discharge to another facility without the department's consent for approximately ten days.

Benthic macroinvertebrates were not collected for this study due to extreme flooding. Without this information, a complete inspection of the facility's impact on the receiving waters could not be made.

Methods

The focus of this investigation was to determine the discharger's effects on the receiving waters. A comparison of biological community health was to be made between a control site (located in East Canal, 100 meters upstream of Knight's Griffin Road) and a test site (located in East Canal, 100 meters downstream of Knight's Griffin Road), however no benthic data was collected due to flooding (see maps in Appendix).

Supplemental physical/chemical data were also collected on the effluent and study sites. The effluent was analyzed for nutrients, metals, and for organic constituents (base neutral and acid extractables, and pesticide extractables). Methods used for all chemical analyses are on file at the DEP Central Chemistry Laboratory in Tallahassee.

Acute screening toxicity bioassays, using the invertebrate, *Ceriodaphnia dubia* and the fish, *Cyprinella leedsi*, as test organisms, were performed on an effluent sample.

Phytoplankton were sampled at both control and test sites via subsurface grabs. Chlorophyll *a* was also determined for phytoplankton communities. *Selenastrum capricornutum* was used as the test organism for the algal growth potential tests.

All field and laboratory biological methods were carried out following Biology Section Standard Operating Procedures (SOP's). The latest version of the SOP's can be viewed on our web site: "www.dep.state.fl.us/labs/sops.htm".

Several different measurements of algal community health have been employed to determine the effects of the discharge. These measurements include: taxa richness, Shannon-Weaver Diversity Index, and algal biomass. For a discussion of each of these measures see the *Explanation of Measurements of Community Health* in Appendix.

Results

A habitat assessment was not performed due to flooding. Dissolved oxygen was highest at the effluent (10.2 mg/L) and fairly low at the control site (5.5 mg/L) and the test site (4.4 mg/L) (see Physical/ Chemical Data Sheets in Appendix). The dissolved oxygen concentration at the test site represents a violation of Class III water quality standards (Rule 62-302.530(31) FAC). The pH was neutral at the test site (7.0 SU) and slightly basic at the control site (6.4 SU), and in the effluent (6.7 SU). Conductivity was lowest at the control site (195 $\mu\text{mhos/cm}$) and somewhat higher at the test site (302 $\mu\text{mhos/cm}$). Conductivity of the effluent was 821 $\mu\text{mhos/cm}$. The temperature ranged from 21.3 °C at the effluent to 17.7 °C at the control site (Table 1).

The facility's effluent was not toxic to the invertebrate, *Ceriodaphnia dubia*, or to the fish, *Cyprinella leedsi*.

The herbicide, atrazine, was detected in the facility's effluent (0.14 $\mu\text{g/L}$) at a concentration below chronically toxic levels (ACQUIRE 1991).

Aluminum, copper, iron, lead, and zinc were detected in the facil-

ity's effluent. All levels complied with Class III water quality standards (Table 1).

Most of the nutrients were higher at the control site than at the test site (Table 1). Ortho-phosphate was 0.64 mg/L at the control site and 0.46 mg/L at the test site. Total phosphorus followed the same trend, with 0.76 mg/L at the control site and 0.58 mg/L at the test site. Ammonia values were also higher at the control site (0.12 mg/L) than at the test site (0.079 mg/L). Nitrate+nitrite levels, on the other hand, were higher at the test site (0.49 mg/L) than the control site (0.11 mg/L). The effluent value for nitrate+nitrite was 1.8 mg/L. TKN was comparable between the two sites (0.93 mg/L and 0.86 mg/L at the control and test sites, respectively).

Algal Growth Potential (AGP) values at the control site (13.1 mg dry wt/L) and the test site (29.6 mg dry wt/L) were above the 5 mg dry wt/L "problem threshold" for freshwater (Raschke and Schultz 1987). The effluent had an AGP value of 49.1 mg dry wt/L.

The effects of the increased nutrients at the test site can be seen in Figure 1. The phytoplankton communities at the control site had more taxa ($n = 35$) and higher diversity (4.1) than the test site (25 taxa and diversity = 3.9). The algal density was lower at the test site (938 cells/mL) than the control site (1,285 cells/mL), both values were low relative to the nutrient levels. The dominant cell at both sites was *Scenedesmus* sp., a green alga. Chlorophyll *a* was undetected at both sites.

Discussion

The purpose of this investigation was to establish a baseline for the Plant City WWTP as it has changed its outfall from the West-side Canal to the East Canal. This baseline study was requested by Domestic Wastewater Compliance personnel. Benthic macroinvertebrates were not collected for this study due to extreme flooding. Without this information, a complete inspection of the facility's impact on the receiving waters could not be made.

The dissolved oxygen concentration at the test site (4.4mg/L) represents a violation of Class III water quality standards (Rule 62-302.530(31) FAC).

The facility's effluent was not toxic to the invertebrate, *Ceri-*

odaphnia dubia, or to the fish, *Cyprinella leedsii*.

The herbicide, atrazine, was detected in the facility's effluent at a concentration below chronically toxic levels. Aluminum, copper, iron, lead, and zinc were detected in the facility's effluent at levels that complied with Class III water quality standards.

There appear to be sources of nutrients in the receiving waters in addition to the facility's input. With the exception of nitrate+nitrite, nutrients were higher at the control site compared to the test site.

The additional nutrients from the facility seemed to have elevated the test site AGP (29.6 mg dry wt/L), above the already high background levels (13.1 mg dry wt/L) and well above the 5 mg dry wt/L "problem threshold" for freshwater




Figure 1. Effect of discharge on the benthic macroinvertebrate community.

Table 1. Effluent permit limits and summary of chemistry data.

City of PlantCity W W T P	Effluent Sample	Control Site	TestSite
Organic Constituents (µg/L)			
Atrazine	0.14 I	-	-
Metals (µg/L)			
Aluminum	41 I	-	-
Arsenic	40 U	-	-
Cadium	0.02 U	-	-
Chromium	10 U	-	-
Copper	2.8	-	-
Iron	74	-	-
Lead	0.2 I	-	-
Mercury	0.10 U	-	-
Nickel	7 U	-	-
Selenium	50 U	-	-
Silver	0.05 U	-	-
Zinc	15 I	-	-
Nutrients (mg/L)			
Ortho-phosphate	0.054	0.64	0.46
Total phosphorus	0.084 A	0.76	0.58
Ammonia	0.017 I	0.12	0.079
Nitrite+Nitrate	1.8	0.11	0.49
TKN	0.72 A	0.93	0.86
Total Nitrogen	2.5	1.0	1.4
General Phys-Chem Parameters			
D.O. (mg/L)	10.2	5.2	4.4
pH (SU)	6.7	6.4	7.0
Conductivity (µmhos/cm)	821	195	302
Temperature (°C)	21.3	17.7	18.3
Tot. Residual Chlorine (mg/L)	0.01	-	-
Flow (MGD)	8.0	-	-
Hardness (mg CaCO ₃)	172.4	-	-
AGP (mg dry wt/L)	49.1	13.1	29.6
Toxicity			
Bioassay Fish	5% Mortality	-	-
Bioassay Invertebrate	No Mortality	-	-

A - Value reported is the mean of two or more determinations

I - Value reported is less than the minimum quantitation limit, and greater than or equal to the minimum detection limit

U - Material analyzed for but not detected; value reported is the minimum detection limit

Table 2. Major characteristics of algae community structure of control and test sites.

City of Plant City WWTP	Control Site	Test Site
Phytoplankton Algae		
Number of Taxa	35	25
Shannon-Weaver Diversity	4.1	3.9
Chlorophyll a (µg/L)	1.1 U	1.1 U
Algal Density (#/mL)	1284.7	938.3
% Blue-green	16.2	14.2
% Green	46.9	32.3
% Cryptophytes	13.5	19.7
% Diatoms	13.5	18.9
% Prasinophyceae	6.3	11.9
% Other	3.6	3.2
AGP (mg dry wt/L)	13.1	29.6

U - Material analyzed for but not detected; value reported is the minimum detection limit

systems. The effluent had an AGP value of 49.1 mg dry wt/L.

Phytoplankton communities did not reflect the elevated nutrients or AGP values. This may be a result of the flooding or the diversion of the facility's effluent. The control site had more taxa ($n = 35$) and higher diversity (4.1) than the test site (25 taxa and diversity = 3.9). The algal density was low and chlorophyll a was undetected at both sites.

This study did not effectively examine the impacts of the facility's effluent on the receiving waters due to the flooding in the canal and the diversion of the effluent by the facility for approximately 35% of the study period.

tal Research Laboratory, Duluth, Mn.

Miller, W. E., T. E. Maloney, and J. C. Greene. 1978. The *Selenastrum capricornutum* Printz algal assay bottle test. U. S. Environ. Prot. Agency, EPA-600/9-78-018. 126 p.

Raschke, R. L. and D. A. Schultz. 1987. The use of the algal growth potential test for data assessment. J. Wat. Poll. Cont. Fed. 59(4): 222-227.

Ross, L. T. 1990. Methods for aquatic biology. Fla. Dept. Environ. Reg. Tech. Ser. 10(1): 1-47.

Weber, C. I. 1993. Methods for measuring the acute toxicity of effluents to freshwater and marine organisms. 4th edition. EPA/600/4-90/027F. U. S. EPA, Cincinnati, Ohio. 216 pp.

Literature Cited

Aquatic Toxicity Information Retrieval Data Base (ACQUIRE). 1991. U.S. EPA Environmen-

Typical Values for Selected Parameters in Florida Waters

Adapted from Joe Hand, FDER, personal communication, 1991

(data was collected between 1980 and 1989)

Percentile Distribution

Parameter	5 %	10%	20%	30%	40%	50%	60%	70%	80%	90%	95%
-----------	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

STREAMS

(1617 stations)

Phytoplankton Chlorophyll <i>a</i>	0.22	0.52	0.94	1.60	3.02	4.63	6.72	9.87	14.68	27.35	48.70
Periphyton Chlorophyll <i>a</i>	0.31	0.43	0.77	1.04	2.16	2.94	6.45	10.51	17.00	39.51	60.85
H-D Diversity	0.84	2.12	2.48	2.74	2.88	3.09	3.25	3.40	3.52	3.76	3.90
Qualitative Taxa Richness	9.00	12.00	17.00	20.00	22.00	24.50	26.00	28.00	31.00	37.00	53.00
H-D Taxa Richness	6.00	6.50	9.00	11.50	13.00	15.00	17.00	21.50	26.00	29.00	32.00
TKN	0.30	0.39	0.56	0.73	0.87	1.00	1.11	1.26	1.49	1.93	2.80
Ammonia	0.02	0.02	0.04	0.05	0.06	0.08	0.11	0.14	0.20	0.34	0.60
NO ₂ -NO ₃	0.01	0.01	0.03	0.05	0.07	0.10	0.14	0.20	0.32	0.64	1.05
Total Phosphorus	0.02	0.03	0.05	0.06	0.10	0.13	0.18	0.25	0.39	0.74	1.51
Ortho Phosphate	0.01	0.01	0.03	0.04	0.05	0.08	0.11	0.17	0.27	0.59	1.37
Turbidity	0.60	0.90	1.20	1.45	2.10	2.80	3.60	4.50	6.65	10.45	16.30

LAKES

(477 stations)

Phytoplankton Chlorophyll <i>a</i>	0.80	1.71	2.88	4.28	10.06	13.40	20.00	30.10	47.20	65.44	113.90
Dredge Diversity	0.71	0.97	1.43	1.74	1.98	2.12	2.21	2.59	2.85	3.15	3.17
Dredge Taxa Richness	3.00	5.00	6.50	7.00	9.00	10.00	11.00	13.00	15.00	17.00	21.00
TKN	0.36	0.49	0.67	0.83	1.08	1.26	1.40	1.51	1.68	2.11	3.46
NH ₃ +NH ₄	0.01	0.02	0.02	0.03	0.04	0.06	0.08	0.12	0.15	0.21	0.28
NO ₂ -NO ₃	0.00	0.00	0.01	0.01	0.01	0.02	0.04	0.05	0.10	0.14	0.23
Total Phosphorus	0.01	0.02	0.02	0.03	0.05	0.07	0.09	0.11	0.14	0.23	0.42
Ortho-Phosphate	0.00	0.01	0.01	0.02	0.03	0.04	0.05	0.06	0.08	0.21	0.32
Turbidity	1.00	1.25	1.55	2.05	2.75	4.50	6.45	9.60	14.10	26.00	40.00


ESTUARIES

(690 stations)

Phytoplankton Chlorophyll <i>a</i>	2.14	3.28	4.49	5.13	6.00	6.93	7.94	9.60	12.40	17.60	22.20
Dredge Diversity	1.34	1.53	1.91	2.28	2.56	2.90	3.15	3.59	4.01	4.53	4.98
Dredge Taxa Richness	4.00	6.00	9.00	11.00	15.00	18.50	25.00	35.00	41.00	62.00	90.00
TKN	0.26	0.34	0.42	0.50	0.59	0.69	0.76	0.82	0.95	1.30	1.49
NH ₃ +NH ₄	0.01	0.02	0.03	0.04	0.05	0.06	0.08	0.09	0.13	0.22	0.28
NO ₂ -NO ₃	0.00	0.00	0.01	0.01	0.01	0.02	0.03	0.05	0.08	0.17	0.23
Total Phosphorus	0.01	0.02	0.06	0.07	0.10	0.11	0.14	0.17	0.23	0.43	0.59
Ortho-Phosphate	0.01	0.02	0.03	0.04	0.04	0.05	0.07	0.09	0.12	0.21	0.44
Turbidity	3.50	4.00	4.50	5.05	5.40	5.60	6.30	6.80	8.00	11.40	11.75

Units:

Phytoplankton Chlorophyll *a* (ug/L), Periphyton Chlorophyll *a* (mg/m²), Nutrients (mg/L), Turbidity (NTU), Taxa richness and diversity values are for macroinvertebrates



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION
FACILITY SUMMARY

Facility Name: <u>City of Plant City WWTP</u>		Date Summary Prepared: <u>2/27/98</u>	
Location (attach detailed map):	County: <u>Hillsborough</u>	District: <u>SW District</u>	
Federal Permit # <u>FL0026557</u> and expiration date: <u>2/19/2002</u>	State GMS # and <u>29-264610</u> State expiration date: <u>2/19/2002</u>	Facility Type: <input checked="" type="checkbox"/> Industrial <input checked="" type="checkbox"/> <u>Municipal</u> Federal Agricultural Other (list):	
Function of facility: <u>Domestic wastewater treatment and disposal site</u>			
Description of treatment process: <u>This is a TYPE I ACTIVATED SLUDGE plant w/ screening and degritting, followed by aeration & clarification. Flow is "polished" in a hyacinth treatment pond, then filtered, chlorinated and re-aerated and dechlorinated prior to discharge. A portion of the flow is reused and not discharged to surface waters.</u>			
Receiving waters: <u>East Canal</u>		Classification: <input type="checkbox"/> I <input type="checkbox"/> II <input checked="" type="checkbox"/> III	
Design Flow: <u>8.0</u>	Mean Flow: <u>6.0 MGD, 3 month ADF</u>	Flow during survey: <u>8.0 MGD</u> <u>(6.0 to surface waters)</u>	
Discharge is: <input checked="" type="radio"/> Continuous <input type="radio"/> Intermittent <input type="radio"/> Seasonal <input type="radio"/> Rainfall dependent Other (describe): therefore, the best time to sample is:			
If facility has a mixing zone, give details (size, parameters affected, etc.): <u>N/A</u>			
List effluent limits (if necessary, attach relevant paperwork):		Describe special permit conditions and permit modifications:	
Parameter	Limit (units)		
See attachments			

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION
FACILITY SUMMARY

(Facility)

Description of permitted outfall(s):

Outfall is to East Canal at $28^{\circ}04'39''$ N \pm $82^{\circ}07'22''$ West, with a short CASCADE STRUCTURE PRIOR TO ENTERING SURFACE WATERS.

List permit violations (from MOR data or other source) and plant upsets that occurred within past year:

Outfall Discharge started 3/1/98, with a 3-month period to achieve compliance. See attached letter for specific violation from 6/1-8/1/97. Additional violations occurred, many attributable to excess rains causing plant upsets. TN and TP violations have occurred in Oct 97-Jan 98, see attached worksheet.

Describe previous impact bioassessments, WQBEL's, and previous or current enforcement actions:

new discharge as of 3/1/97

Warning letter ISSUED 9/24/97: NEGOTIATIONS ON-GOING.

Discuss comparability of MOR results to past DER results and whether there are trends (improving, declining) in the data set:

N/A

Additional information:

Staff contributing to this review (signature):

Andrea Granger (Biologist)

Joe Gustafson (Inspector)

[Signature] (Engineer)

()

()

()

PERMITTEE: City of Plant City
Post Office Drawer C
Plant City, Florida 33564
FACILITY: Plant City WRF

PERMIT NUMBER: FL0026557
EXPIRATION DATE: 2/19/2002
APPLICATION NO.: 29-264610

4. Outfall D002 to the East Canal. During the period beginning upon placing the new and modified facilities into operation and lasting through the expiration date of this permit, the permittee is authorized to discharge effluent from Outfall D002 to the East Canal north of Knights Griffin Road (County Road 582) east of State Road 39. Such discharge shall be limited and monitored by the permittee as specified below:

Parameter	Units	Maximum/Minimum	Effluent Limitations				Monitoring Requirements			Notes
			Annual Average	Monthly Average	Weekly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number	
Flow	mgd	Maximum	2.68 (1)	-	-	-	Continuous (2)	RFMT (3)	OUT-02	See Condition I. A. 7.
Carbonaceous Biochemical Oxygen Demand (five day)	mg/L	Maximum	5.0	6.25	7.5	10.0	Daily, 5/wk (2)	FPC - 24 (4)	OUT-02	
Total Suspended Solids	mg/L	Maximum	5.0	6.25	7.5	10.0	Daily, 5/wk (2)	FPC - 24 (4)	OUT-02	See Condition I. A. 13.
Total Nitrogen	mg/L	Maximum	3.0	3.75	4.5	6.0	Daily, 5/wk (2)	FPC - 24 (4)	OUT-02	
Total Phosphorus	mg/L	Maximum	1.0	1.25	1.5	2.0	Daily, 5/wk (2)	FPC - 24 (4)	OUT-02	
Total Residual Chlorine (for dechlorination)	mg/L	Maximum	-	-	-	0.01	Continuous (2)	Meter	OUT-02	
Fecal Coliform Bacteria	See Permit Condition I. A. 9.						Daily, 5/wk (2)	Grab	OUT-02	
Dissolved Oxygen	mg/L	Minimum	-	-	-	5.0	Daily, 7/wk (2)	Grab	OUT-02	
Whole Effluent Toxicity							Every six months	Three FPC - 24 (4)	OUT-02	See Condition I. A. 12.

(1) Discharge of reclaimed water in excess of the stated flow rate shall be permitted under the following conditions:

(a) In the event of any force majeure, including without limitation, any hurricane, tropical storm, reuse distribution system line breakage, or other extraordinary event beyond the reasonable control of permittee, the permittee shall be allowed to discharge sufficient flow to maintain wastewater facility functionality and operation.

(b) During any period of time that reuse by any year-round industrial or commercial user, including without limitation CF Industries or Lloyd & Rings Nursery, is interrupted due to facility maintenance, construction, emergency or other abnormal operating condition at the industrial or commercial user's facility reduces the combined consumption of such facilities to less than 2.395 mgd, then permittee shall be permitted to discharge to Outfall 002 any such volume not so consumed to OUT-002.

(2) During discharge.

(3) RFMT = Recording Flow Meter and Totalizer.

(4) FPC - 24 = Flow-proportioned composite sample taken during a period of twenty-four hours.

5. Effluent samples shall be taken at the monitoring site locations listed in Permit Conditions I. A. 1. Through I. A. 4. and as described below:

Monitoring Location Site Number	Description of Monitoring Location
PPI-01	Discharge from the clarifiers
PPI-04	Discharge from CCC-1, the chlorine contact chamber between the clarifiers and the polishing pond
OUT-01	Outfall D001 to the Westside Canal
OUT-02	Outfall D002 to the East Canal

6. Hourly measurement of total residual chlorine for disinfection during the period of required operator attendance may be substituted for continuous measurement. [62-601, Figure 2, Footnote 2, 5/31/93]
7. Recording flow meters and totalizers shall be utilized to measure flow and shall be calibrated at least annually. [62-601.200(17) and .500(6), 5/31/93]
8. Basic Level Disinfection. The arithmetic mean of the monthly fecal coliform values collected during an annual period shall not exceed 200 per 100 mL of effluent sample. The geometric mean of the fecal coliform values for a minimum of ten samples of effluent each collected on a separate day during a period of thirty consecutive days (monthly), shall not exceed 200 per 100 mL of sample. No more than 10 percent of the samples collected during a period of thirty consecutive days shall exceed 400 fecal coliform values per 100 mL of sample. Any one sample shall not exceed 800 fecal coliform values per 100 mL of sample. [62-600.440(4)(c), 6/8/93]
9. Intermediate Disinfection. The arithmetic mean of the monthly fecal coliform values collected during an annual period shall not exceed fourteen per 100 mL of effluent sample. The median value of the fecal coliform values for a minimum number of ten samples of effluent each collected on a separate day during a period of thirty consecutive days (monthly), shall not exceed fourteen per 100 mL of sample. No more than 10 percent of the samples collected during a period of thirty consecutive days shall exceed forty-three fecal coliform values per 100 mL of sample. Any one sample shall not exceed eighty-six fecal coliform values per 100 mL of sample. [62-600.440(6)(c), 6/8/93]
10. A minimum of 0.5 mg/L total residual chlorine must be maintained for a minimum contact time of fifteen minutes based on peak hourly flow. [62-600.440(4)(b), 6/8/93]
11. Florida water quality criteria and standards shall not be violated as a result of the discharge. [62-600.500, 6/8/93]
12. The permittee shall perform the series of tests described below to evaluate whole effluent toxicity of the discharges. All test species, procedures, and quality assurance criteria used shall be in accordance with the procedures included in the EPA publication entitled Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Water to Freshwater Organisms, EPA/600/4-91/002, Third Edition, July 1994, or the most current edition. The publication as described above is referred to as "EPA Chronic Toxicity" and the reference shall mean the most current edition of the publication. The control and dilution water will be moderately hard water as described in Table 3 of Section 7.2.3 in EPA Chronic Toxicity. A standard reference toxicant quality assurance chronic toxicity test shall be conducted concurrently with each species used in the toxicity tests, and the results submitted with the bioassay report. Additionally, monthly QA/QC reference toxicant test results must be submitted. Any deviation from the bioassay procedures outlined herein shall be submitted in writing to the Department for review and approval prior to use.



Department of Environmental Protection

Lawton Chiles
Governor

Southwest District
3804 Coconut Palm Drive
Tampa, Florida 33619

Virginia B. Wetherell
Secretary

**CERTIFIED MAIL
RETURN RECEIPT REQUESTED**

Nettie Draughon, City Manager
City of Plant City
1802 West Spooner Drive
Plant City, FL 33566-9288

September 24, 1997
Hillsborough County

PL
PL2
PL3

WARNING LETTER NUMBER WL97-0021DW29SWD

Re: City of Plant City WWTP / Permit No. FL0026557

MODS from 10/31
may

Nettie
Dear ~~Ms. Draughon~~:

Inspections conducted of the referenced facility on April 29, and July 30, 1997, by Department personnel and a review of the information on file indicates that a violation of Chapter 403 [and/or Chapter 376], Florida Statutes, and the rules promulgated thereunder may exist at the above described facility. Department personnel observed the following:

1. The effluent is not in compliance with the limits imposed by the permit.
 1. Permit exceedances reported on the June discharge monitoring report ("DMR") for effluent discharged to the public-access reuse system are as follows:
 - a. Fecal Coliform single sample limit of 25 cts/100ml: 6/2 - 245; 6/9 - 58; 6/13 - 60. ✓
 - b. The minimum TRC of 1.0 mg/l was not met on eight separate days in June. 6 DAYS
 - c. The single sample limit of 5 mg/L for TSS: 6/23 - 5.2; 6/26 - 5.5; 6/27 - 11.5; 6/29 - 5.5. ✓
 2. Permit exceedances reported on the June DMR for effluent discharged to the East Canal are as follows:
 - a. The single sample limit of 5 mg/L for TSS: 6/24 - 16.3. ✓
 - b. Fecal Coliform single sample limit of 86 cts/100ml: 6/2 - 282; 6/4 - 150; 6/5 - 580; 6/13 - 600; ✓
6/19 - 280; 6/23 - 580; 6/25 - 350.
 - c. The monthly and annual limit for fecal coliform of 14 cts/100ml was exceeded with averages of 59 and 18.3.
 3. Permit exceedances on the July DMR for the effluent discharged to the East Canal are as follows:
 - a. Fecal Coliform, at the DRF, single sample limit of 86 cts/100ml: 7/4 - 1210; 7/9 - 2400; 7/10 - 360; 7/11 - 6000; 7/16 - 2100; 7/17 - 500; 7/18 - 200; 7/22 - 1200; 7/25 - 130; 7/30 - 90. ✓
 - b. The maximum TRC of 0.01 mg/l at the DRF was not met on three separate days in July. 2 days

c. The monthly and annual limit for fecal coliform of 14 cts/100ml was exceeded with averages of 165 and 47.6. ✓

4. Permit exceedances reported on the July DMR for effluent discharged to the public-access system are as follows:

- a. The minimum TRC of 1.0 mg/l was not met on six separate days in July. *delete*
- b. The single sample limit of 5 mg/L for TSS: 7/31 - 6.2. ✓

5. From abnormal events reported to the DEP for the discharge to the East canal:

- a. Fecal Coliform single sample limit of 86 cts/100ml: 8/6 - 190; 8/21 - 25,700; 8/22 - 160. ✓
- b. Fecal Coliform single sample limit of 86 cts/100ml: 9/2 - 200; 9/3 - 180. ✓

2. The sampling schedule and collection method imposed in the permit has not be followed.

- 1. None of the composite samplers were set to take flow-proportioned composites. *no change, but fixed*
- 2. All strainers for the composite samplers were attached to the side walls. *no change, but fixed*
- 3. Numerous samples were not collected for June and July as required by the permit. *no change, but fixed*

3. Proper calibration of equipment used for compliance purposes is not being maintained.

- 1. The in-line meters (Chlorine, pH and Turbidity) must be calibrated with standards weekly, with the procedure and results documented. The meters are only checked daily against another meter. *no change, but fixed*
- 2. The influent flow meter had not been calibrated for over a year. *no change, but fixed*
- 3. The flow meter for the discharge to the East Canal has not been recording properly. A calibration has been requested previously, but never submitted. *no change, but fixed*

4. The Operating Protocol for the public-access reuse system is not being followed.

- 1. The in-line turbidity meter was not in service, as required by the approved operating protocol. Days in which the equipment was reported or found off line are 6/8 and 7/31. However, reclaimed water was being sent to the public-access reuse system. *no change*
- 2. The in-line chlorine analyzer was not in service, as required by the approved operating protocol. Days in which the equipment was reported or found off line are 6/1 - 4, 6/28/ 6/30, 7/8, 7/15, 7/27, 7/29, 8/1 - 4, 8/15, 8/18, 9/5. However, reclaimed water was being sent to the public-access reuse system. *no change*

3. It appears that for a given turbidity value above the reject setpoint, a sample is taken and analyzed to confirm a TSS >5 prior to reject. Reject may be delayed in excess of one hour. *no change*
4. Numerous times reports have been provided showing flow to the reuse system occurred when the total residual chlorine was below 1.0 mg/l or the turbidity was over 2.5 NTUs for over ten minutes, or when either in-line meter was out of service. *no change*
5. The compliance schedule of the permit issued 2/19/97 was not followed. *not applied for*
 1. Section VII. 4. contained a compliance schedule for the pretreatment program; a preliminary draft of the local limits and sewer use ordinance ("SUO") was due to be submitted by June 30, 1997; only the SUO was submitted.

STATUTES AND RULES ALLEGEDLY VIOLATED:

1. To violate or fail to comply with any permit issued by the Department pursuant to its legal authority; 403.161(1)(b), Florida Statutes.
 2. To fail to meet the effluent limits imposed for a discharge to a tributary of the Hillsborough River; 403.086(4)(b), Florida Statutes.
 3. To fail to calibrate flow meters on an annual basis; Rule 62-601.500(6), Florida Administrative Code ("FAC").
 4. To fail to comply with the minimum sampling schedule for sampling and testing parameters at a wastewater treatment plant; Rule 62-601.500(2), FAC.
 5. To fail to take flow-proportioned composite samples; Rule 62-601.500(3)(c), FAC.
 6. To fail to meet the effluent limits, TSS and fecal coliform, for discharge to a public-access reuse system; Rule 62-610.460(1), FAC.
 7. To fail to have continuous monitoring equipment for TRC and turbidity and the failure to properly calibrate the on-line equipment; Rule 62-610.463(2), FAC.
 8. To fail to follow an approved operating protocol; Rule 62-610.460(2), FAC.
- To fail to take a representative sample due to the location of the strainers on the composite samplers; Rule 62-160.300(5), FAC and specifically 4.2.4.4 of DER-QA-001/92.

Operation of a facility in violation of state statutes or rules may result in liability for damages and restoration, and the judicial imposition of civil penalties up to \$10,000 per violation per day pursuant to Sections 403.141 and 403.161, Florida Statutes. In applying the *Guidelines for Characterizing Domestic Wastewater Violations* to the alleged violations, a penalty in excess of \$10,000 has been calculated.

YOU ARE REQUESTED TO CONTACT Joe Squitieri of this office at 744-6100, Extension 309 within 15 days of receipt of this Warning Letter to arrange a meeting with Department personnel to discuss the issues raised in this Warning Letter. You may wish to consult an attorney and to have the attorney attend the meeting with the Department.

PLEASE BE ADVISED that this Warning Letter is part of an agency investigation preliminary to agency action in accordance with Section 120.57(4), Florida Statutes. The purpose of this letter is to advise you of potential violations and to set up a meeting to discuss possible resolutions to any potential violations that may have occurred for which you may be responsible. If the Department determines that an enforcement proceeding should be initiated in this case, it may be initiated by issuing a Notice of Violation or by filing a judicial action in accordance with Section 403.121, Florida Statutes. If the Department issues a Notice of Violation, and you are named as a party, you will be informed of your rights to contest any determination made by the Department in the Notice of Violation. The Department can also resolve any violation through entry into a Consent Order.

Sincerely,



Richard D. Garrity, Ph.D.
Director of District Management
Southwest District

cc: Chris Dunn P.E. HCEPC
David York, DEP-Tall. (e mail)
Jennifer Fitzwater, OGC (e mail)
Ed Snipes, DEP-SWD (e mail)
Mike Hickey, DEP-SWD (e mail)

Rain 4 - 3.45 , 1 - 1.82
12 1.0 13 - 2.7 27 - 3.56

Dec. 97

Flow assessment
~~Abn events~~ 6, 7, 8, 9, 13, 16, 18, 19, 21, 31

TRE decoder 12/29 - 0.44

TK - 12/1 - 6.4

TP - 12/1 - 6.9

12/3 7.0

2 - 3.9

12/4 7.2

3 - 6.0

12/5 6.9

4 - 3.8

12/8 6.4

5 - 2.9

weekly 1st - 6.67 8th - 5.9

8 - 7.5

monthly av - 3.75

9 - 4.7

10 - 3.2

11 - 3.0

12 - 3.0

15 - 8.4

16 - 2.9

17 - 3.1

18 - 2.9

19 - 2.9

Av. Flow - 2.48

(limit is 2.68)

22 - 2.3

23 - 2.3

Fecals - Annual Av - 30

weekly - ALL 1 - 4.71

8 - 4.30

15 - 2.82

22 - 1.84

monthly av. 1.25

Annual 1.29

Nov 97

Flows above 8.0 - none

TPW - 3 9.56
4 9.85
5 11.15
6 12.89
7 10.98
10 8.66
11 10.14
12 9.28
13 9.44
14 9.67
24 7.39
~~27~~ 5.62
25 6.8

Weekly - all 4

Monthly - 7.88

TRC - 11/14 - 0.049 (72 mins)
11/22 .15 (10 mins)
Feed, DODI - 11/7 - 15,000
11/25 - 5,000

Escal Annual - 33

Feed RCOI 12/26 - 58

TP - 3 2.47
4 2.54
5 4.03
6 2.88
7 2.5
11 2.5
12 6.85
13 7.64
14 2.22
17 4.08
18 4.27
19 4.71
20 4.25
21 4.35
24 6.41
25 6.17
26 4.38
27 4.33
28 4.54

Weekly - all

Monthly - 1.25

Annual - 1.08

Oct.

Flow > 8.0 mgd - 3, 4

TSS - DOOL -

10/7 17.5

10/8 10.8

11 6.6

12 7.4

14 7.2

16 13.7

17 6.8

20 6.0

21 6.8

TP - 1 - 4.22

2 - 3.82

3 - 2.12

13 - 2.17

14 - 2.24

15 - 2.05

16 - 2.99

20 - 2.37

21 - 2.05

29 - 2.61

30 - 2.16

TN

1 9.88

2 9.56

3 7.2

13 11.89

14 10.37

15 7.88

16 8.68

17 19.74

21 9.45

27 7.05

28 6.11

29 8.98

30 6.60

31 6.35

TRC dechlor 1 0.71

TRC disin 1 .8

2 .5

Fecal DOO2 1 550

2 1400

3 10,000

Ammonia - 37

Fecal ROOI monthly - 10

TRC < 1 10/1 - .8 (1 hr)

10/2 .5 (10 hr)

TRC > 0.1 10/1 .708 (12 hrs)

FDEP Biology Section — Acute Bioassay Bench Sheet

Sample Source: Plant City WWT
 County:
 Contact / District: K. Edwards SW Dist
 NPDES Permit #: FL0026557
 LIMS Sample #: 310254 LIMS Job #: 1998-03-04-01

Sample Collection: Date 3/2/98 Time 0919
 Test Beginning: Date 3/3/98 Time 1440
 Test Ending: Date 3/4/98 Time 13:45
 Organism Batch #: 12 Diluent Batch #: 10
 Organism Age: <24 hours
 Test Organism: Coriodaphnia dubia

sample log: 3/6/98 DW
 Test Type: Screening Definitive
 (Static | Static Renewal | Flow-through)
 Temperature range: room 24.0-25.0°C
 incubator 23.9-25.4
 Test Number: 1 of 2
 Remarks: D = dead, M = missing

Instrument Calibrations: pH meter # 7851
 Temperature °C 90H018262
 D.O. mg/L 90H018262
 Conductivity μ mhos/cm G9005749
 0 hr 7.0 @ 7.0 21.7 @ 21.7 8.2 @ 24.8 °C 98.4 @ 96.3
9.0 @ 9.0 98.1 @ 100.5 @ 24.2 °C
 24 hr 7.0 @ 7.0 22.1 @ 22.1 8.2 @ 24.9 °C 98.0 @ 96.3
9.0 @ 9.0 99.0 @ 100.5 @ 24.5 °C
 48 hr 7.0 @ 7.0 22.4 @ 22.4 9.2 @ 25.2 °C 99.6 @ 96.3
9.0 @ 9.0 99.5 @ 100.5 @ 24.1 °C

(3) mistake

Conc.	Chamber #	Number Live			pH			Temperature (°C)			D.O. (mg/L)			UNCORRECTED Cond. (mmhos/cm)		
		0 hr	24 h	48 h	0 hr	24 h	48 h	0 hr	24 h	48 h	0 hr	24 h	48 h	0 hr	24 h	48 h
Control A	A	5	5	5	8.2	9.0	9.0	22.2		23.6	7.9	7.4	7.4	165		258
Control B	B	5	5	5		8.0	8.0			23.6		7.6	7.6			184
Control C	C	5	5	5		8.1	8.1			23.4			7.5			195
Control D	D	5	5	5		8.0	8.0			23.2			7.7			201
100% A	A	5	5	5	7.6	8.0	8.0	22.6		23.6	8.6		7.4	700		705
100% B	B	5	5	5		8.1	8.1			23.5			7.6			794
100% C	C	5	5	5		8.2	8.2			23.5			7.5			824
100% D	D	5	5	5		8.3	8.3			23.4			7.6			882
										23.2			7.5			
Measured/Loaded by:		MF	MF	FW	MF		DAW	MF		DAW	MF		DAW	MF		DAW
Recorded by:		MF	MF	FW	MF		FW	MF		FW	MF		FW	MF		FW

Investigators' Signatures

Marshall Faircloth
James Marshall
David Whiting

Salt Water

Water Quality Parameters

Well Water | 20% Min Water | Sample | Method | Measured by

Field Total Residual Cl₂ (mg/L): 0.01
 Lab Total Residual Cl₂ (mg/L): 10.03
 Alkalinity (mg/L as CaCO₃): 72
 Hardness (mg/L as CaCO₃): 90
 Total ammonia (mg/L as N): 20.017
 Ammonia Ammonia Ammonia Control
 Meter #98136 Meter Slope: -58.1 Blank: 20.017 Salinity: 0 ppt Sample Salinity: 0 ppt

reviewer

form updated 4/01/96

Phytoplankton taxa list and densities (#/mL) for City of Plant City WWTP, collected via subsurface grabs in East Canal, on 02 March, 1998.

	Control Site	Test Site
Bacillariophyceae		
<i>Cocconeis</i> sp.	12	15
<i>Cyclotella</i> sp.	6	—
<i>Cylindrotheca</i> sp.	6	15
<i>Melosira</i> sp.	69	7
<i>Navicula</i> sp.	6	22
<i>Neidium</i> sp.	6	—
<i>Nitzschia</i> sp.	29	74
Undetermined Pennate diatom	41	44
Chlorophyceae		
<i>Actinastrum</i> sp.	—	7
<i>Chlamydomonas</i> sp.	75	15
<i>Chlorogonium</i> sp.	6	—
<i>Coelastrum</i> sp.	—	7
<i>Cosmarium</i> sp.	6	—
<i>Crucigenia</i> sp.	23	15
<i>Dunaliella</i> sp.	127	7
<i>Euastrum</i> sp.	6	—
<i>Pandorina</i> sp.	6	—
<i>Scenedesmus</i> sp.	272	199
<i>Schroederia</i> sp.	12	—
<i>Selenastrum</i> sp.	—	7
<i>Staurastrum</i> sp.	6	7
<i>Tetraedron</i> sp.	6	7
<i>Tetrastrum</i> sp.	6	7
Undetermined Chlorophyceae	52	22
Chrysophyceae		
<i>Dinobryon</i> sp.	6	—
<i>Mallomonas</i> sp.	12	—
<i>Synura</i> sp.	6	7
Cryptophyceae		
<i>Chroomonas</i> sp.	81	59
<i>Cryptomonas</i> sp.	93	126
Cyanophyceae		
<i>Anabaena</i> sp.	6	—
<i>Dactylococcopsis</i> sp.	133	96
<i>Merismopedia</i> sp.	58	37
<i>Microcystis</i> sp.	12	—
Dinophyceae		

<i>Ceratium</i> sp.	6	—
Euglenophyceae		
<i>Euglena</i> sp.	12	22
<i>Phacus</i> sp.	6	—
Prasinophyceae		
<i>Pyramimonas</i> sp.	75	81
<i>Spermatozoopsis</i> sp.	6	30

Fill Out This Section For All Surface Water Discharger Inspections (CEI, CSI, CBI, PAI, XSI - RI Optional)

Transaction Code			NPDES NUMBER					YR/MO/DA				Insp Type	Inspector	Fac Type														
1	N	2	5	3	F	L	0	0	2	6	5	5	7	11	12	9	8	0	3	0	2	17	18	X	19	S	20	I
Remarks																												
<div style="display: flex; justify-content: space-between;"> 21 66 </div>																												

Fill Out This Section For All Surface Water Discharger Inspections (CEI, CSI, CBI, PAI, XSI - RI Optional)

Transaction Code			NPDES NUMBER					YR/MO/DA				Insp Type	Inspector	Fac Type														
1	N	2	5	3	F	L	0	0	2	6	5	5	7	11	12	9	8	0	3	0	2	17	18	B	19	S	20	I
Remarks																												
<div style="display: flex; justify-content: space-between;"> 21 66 </div>																												